File E150057 Project 95RT5539

Issued: November 14, 1995 Revised: March 24, 2020

REPORT

on

COMPONENT - MISCELLANEOUS HEATERS

STEGO Elektrotechnik GmbH Schwaebisch Hall

Copyright $_{\odot}$ 1995 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above-named company to reproduce this Report provided it is reproduced in its entirety. Underwriters Laboratories Inc. authorizes the above-named company to reproduce the latest pages of that portion of this Report consisting of this Cover Page through Page 2.

File E150057	Vol. 1	Sec. 4	Page 1	Issued:	1995-11-14
		and Report		Revised:	2020-03-24

DESCRIPTION

PRODUCT COVERED:

* USR, CNR Component Air-Heaters for Models HGK 047ZZ.Y-XX where "ZZ" may be 00, 01, 02, "Y" may be 9, "XX" may be 00 to 99.

NOMENCLATURE - ELECTRICAL RATING:

*

Model HGK 047 Series:

HGK 047ZZ.Y-XX

HGK - Heater Type <u>047</u> - PTC Heater Basic Design

 $\frac{ZZ}{D0} = Heater Power$ 00 = 10W 01 = 20W 02 = 30W

 \underline{Y} - Supply Voltage 9 = 120 - 230 Vac/dc

 $\frac{XX}{00}$ - Cable Length Code 00 - 99 = customer code for cable length up to 3000 mm

ENGINEERING CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE'S USE):

 \mbox{CNR} - Indicates the air heaters comply with Canadian Standard CAN/CSA C22.2 No. 72.

This product is intended for installation within industrial control panels, control boxes, etc. to keep the internal temperature at a suitable level.

The product is for use only in complete equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

File E150057	Vol. 1	Sec. 4	Page 2	Issued:	1995-11-14
		and Report		Revised:	2020-03-24

Conditions of Acceptability - The features which should be considered in determining the acceptability of this heater in the specific applications are indicated below:

1. The heater is intended for use within an enclosure. The suitability is to be determined in the end-use.

2. Maximum surface temperature was: * 93°C for Model HKG 04702.9-XX at 120Vac 92°C for Model HKG 04702.9-XX at 230Vac

in an open air ambient of 25° C. The need for an enclosure, guards or marking should be evaluated in the end-use.

3. The suitability of the cord, strain relief, cord connection method and proximity to hot surfaces should be evaluated in the end-use.

4. The mounting of the product must be evaluated in the end use.

 $5.\ \ \, \mbox{The following tests}$ have been conducted as part of this investigation.

- 1. Input Test
- * 2. Dielectric Withstand Test
- 3. Normal Temperature Test
- * **4.** Insulation Resistance After Moisture Conditioning
- *